



General Notes:

1. Product standards:
Conduits with long bells meet the requirements of UL651, including 90°C rating and sunlight resistance criteria.
2. Material: PVC material meets cell class 12254 per ASTM D 1784.
3. Product listing: conduit is listed by Underwriters Laboratories (UL).
4. Bell outside diameters may vary due to allowable manufacturing tolerances. Diameters listed above are maximum values.
5. Additional information such as sales literature and technical bulletins is available at www.pwpipe.com.

Nominal Pipe Size (inches)	Nominal Bell Length (inches)	Average Pipe Outside Diameter (inches)	Maximum Bell Outside Diameter (inches)
1/2	1.750	0.840	1.375
3/4	2.000	1.050	1.500
1	2.250	1.315	1.875
1 1/4	2.500	1.660	2.250
1 1/2	2.750	1.900	2.500
2	3.250	2.375	3.000
2 1/2	3.500	2.875	3.625
3	4.000	3.500	4.375
3 1/2	4.250	4.000	4.875
4	4.750	4.500	5.500
5	5.800	5.563	6.625
6	6.375	6.625	7.750